

**U. S. Steel Canada – Lake Erie Works
Environmental Management System and Community Engagement Report
July 2 – December 31, 2015**

On March 27, 2015, Lake Erie Works received a Site-Specific Standard Approval for suspended particulate matter from the Ministry of Environment and Climate Change (MOECC) (Approval No. 204-15-rv0). As a part of this Site-Specific Standard Approval, the MOECC issued a related Order (Order No. 204-15-order-rvo) which set visible emission limits for coke plant doors, lids, offtakes and charging.

This Environmental Management System and Community Engagement Report summarizes information as required per Item 3.20.2. of the Order covering the period July 2 to December 31, 2015.

A summary of the information required by Item 3.3 with respect to the notice(s) required to be given.

Lake Erie Works complied with the daily 30-day rolling average visible emission limits. Therefore no notification was required to be submitted to the MOECC District Manager.

A summary of the information required by paragraph 6 of Item 3.9 with respect to the record(s) required to be made.

There were no exceedances of the daily limits for coke battery doors and offtakes. There was one exceedance of the daily limit for topside port lids. The limit is 2%, and the calculated level was 2.5% in one incident. As an operational adjustment, sealant was applied to the leaking lids.

A summary of the information required by paragraph 7 of Item 3.14 with respect to the record(s) required to be made.

Daily fugitive emissions associated with coke oven pushes were in compliance with Item 3.14. Therefore no operational adjustment record was required.

The minutes of the CLC meetings and any related follow-up actions.

The minutes of the 2015 CLC meetings can be retrieved from U. S. Steel Canada's website at:
<http://www.ourcommunityourfuture.com/clc/community-liaison-committee-reports/>